

Speed Post

**GOVERNMENT OF HARYANA
STATE ENVIRONMENT IMPACT ASSESSMENT AUTHORITY
DEPARTMENT OF ENVIRONMENT, HARYANA
SCO NO. 1-3, SECTOR-17-D, CHANDIGARH.**

No. DEH/09/SEIAA/78
To

Dated: 1-4-09

M/S Perpetual Infracon Pvt. Ltd.,
3rd Floor Property No. 202 Block No. 172,
Jor Bag, New Delhi-110001.

Subject: Construction IT/ITES SEZ Project at village Budena, Sector-81,
District Faridabad, Haryana- Environmental Clearance

Dear Sir,

This has reference to your application 28.12.07 addressed to Director, IA Division, MOEF, GOI and received in the office of MS, SEIAA on 03.09.08 and subsequent letter dated 12.11.08 seeking prior environmental clearance for the above project under the EIA Notification, 2006. The proposal has been appraised as per prescribed procedure in the light of provisions under the EIA Notification, 2006 on the basis of the mandatory documents enclosed with the application viz., Form-1, Form1-A & Conceptual Plan and the additional clarifications furnished in response to the observations of the State Expert Appraisal Committee (SEAC) constituted by MOEF, GOI vide their Notification 21.4.2008, in its meetings held on 19th & 20th August, 2008 and 16.12.08 and awarded "Gold" rating to the project.

[2] It is, interalia, noted that the project involves IT/ITES SEZ project on a plot area of 219489 Sq.M. The total built up area is 750269.38 sq. mtrs. The building comprises three level basements. The total cost of the project is more than 412.91 crores. The total water requirement is 5450 KLD and fresh water requirement will be 2590 KLD which will be drawn from existing tubewells for which permission from Central Ground Water Authority has already been obtained. Total 3182 KLD of waste water will be generated which will be treated in the STP of 3820 KLD capacity. 2863 KLD of treated water will be recycled and reused for flushing, horticulture, HVAC make up leading to zero discharge from the unit. Total solid waste generation will be 20097 kgs per day which will be disposed off as per Solid Waste Management & Handling Rules. The power requirement is 52 MW which will be supplied by HSEB. For power backup the project proponent has proposed to install 25 nos. of DG sets of 2000 KVA each. The total parking spaces proposed are for 6126 ECS.

[3] The State Expert Appraisal Committee, Haryana after due consideration of the relevant documents submitted by the project proponent